



GENERAL NOTES:

1. MAXIMUM BARREL EXTENSIONS ARE 18 INCHES AND SHALL BE WATEROUS EXTENSION FOR WATEROUS HYDRANTS.
2. ALL HYDRANTS ARE TO BE SUPPLIED WITH A 6" FLANGED AND MECHANICAL JOINT AUXILIARY VALVE THAT CONFORMS TO AWWA C515. THE GATE VALVE STEM AND WEDGE NUT SHALL CONFORM WITH SECTION 4.4.5.1 OF AWWA 515. ALL TRIM BOLTS ARE TO BE STAINLESS STEEL.
3. THE HYDRANT WILL EXCEED ALL THE REQUIREMENTS OF AWWA C502.
4. RESTRAINED JOINTS ARE REQUIRED THROUGHOUT THE FIRE HYDRANT ASSEMBLY.

REV.:	AK	REV.:	12-11-09
REV.:	ERH	REV.:	3-20-99
DRAWN BY:	VJGL	DATE:	2-16-98

HYDRANT SETTING

VILLAGE OF LOMBARD

WATER 2