

Grease Trap

Maintenance

In House/Contractor

Floating & Bottom Solids $\leq 25\%$ Total Capacity of Trap

-OR-

Quarterly: remove floating materials

2x per Year: remove floating materials and bottom solids

Reporting

Submit Quarterly Report on April, July, Oct, Jan 15th

Manifest

Repairs

Complete within 30 Days

Village Inspections

Every 2 Years or as needed

Grease Interceptors

Maintenance

Contractor

Floating & Bottom Solids \leq 25% Total Capacity of Trap

-OR-

Quarterly: remove floating materials

2x per Year: remove floating materials and bottom solids

Reporting

Submit Quarterly Report on April, July, Oct, Jan 15th

Manifest

Repairs

Complete within 30 Days

Village Inspections

Every 2 Years or as needed